

STATE OF CALIFORNIA - DEPARTMENT OF TRANSPORTATION
Caltrans ELECTRICAL DESIGN

NOTES:

1 RC Exist 120/240 V, 1Ø, 3-WIRE, TYPE A SERVICE.

2 120/240 V, 1Ø, 3-WIRE, TYPE III-AF SERVICE EQUIPMENT ENCLOSURE WITH THE FOLLOWING CIRCUIT BREAKERS:

CTID No. 06410990011962L

AMPERES	VOLTS	POLES	NAMEPLATE	METER	PHOTOELECTRIC CONTROL TYPE
100	240	2	MAIN	YES	—
30	240	2	HIGHWAY LIGHTING	YES	IV
20	240	2	SPARE	YES	—
20	240	2	SPARE	YES	—

3. ALL PULL BOXES SHALL BE No. 5 (E) UNLESS OTHERWISE NOTED.
4. RIGHT OF WAY LIMITS ARE INDETERMINATE, AND ARE NOT SHOWN. THE CONTRACTOR MUST CONTACT RIGHT OF WAY ENGINEERING AT THE DISTRICT OFFICE FOR CONDITIONS OF USE PRIOR TO COMMENCING WORK.

DIST	COUNTY	ROUTE	POST MILES TOTAL PROJECT	SHEET No.	TOTAL SHEETS
06	Mad	99	9.5/13.1		


REGISTERED ELECTRICAL ENGINEER

PLANS APPROVAL DATE

THE STATE OF CALIFORNIA OR ITS OFFICERS OR AGENTS SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OR COMPLETENESS OF SCANNED COPIES OF THIS PLAN SHEET.

REVISOR: OMAR MENDOZA, RAJPREET SINGH

DESIGNER: ALI BAKHDOUD



**COUNT LOOPS
 MODIFY LIGHTING
 E-7**

THIS PLAN IS ACCURATE FOR ELECTRICAL WORK ONLY.

SCALE: 1"=50'