



**DEPARTMENT OF FORESTRY AND FIRE  
PROTECTION**  
OFFICE OF THE STATE FIRE MARSHAL  
Fire and Life Safety Division - North  
2251 Harvard Street, Suite 130, Sacramento, CA 95815  
(916) 568-3826

## SPOT INSPECTION REPORT

### LOCATION INFORMATION

**Building Name:** Oaktown Parking

**Street Address:** Castro

**County:** Alameda

**City, State, Zip code:** Oakland , CA, 94507

**Lot Number:**

**Suite Number:**

**Floor Number:**

**Agency:** Transportation Dept. (CalTrans) (59900)

**SFM File No.:** 14-01-91-0405-10001

### INSPECTION INFORMATION

**Inspection Number :** 152276

**Inspection Type:** Spot Inspection

**Inspection Date :** 11/21/2023

**Inspection Status :** Failed

**Inspector:** Ray Stockton

**Inspection Hours :** 2.25

**Inspector Signature:**

**Travel Hours :** 0.75

**Inspection Comments:**

A Fire and Life Safety Inspection was conducted at CALTRANS District 4, Airspace parcel ALA880, property number 0035, Interstate 880, specific location of 5th Street at Castro Street in Oakland, California, on Tuesday, November 21, 2023 by Deputy State Fire Marshals Ray Stockton and Andrew McSorley. This inspection is for fire and panic safety, and code compliance within the California Department of Transportation (CALTRANS) right-of-way property use. I was accompanied by CALTRANS Staff. The location is an open parking and storage lot. The following deficiencies were noted and shall be correct. See deficiency list.  
End of Report.

**Discussed With:** Jim Bozionelos

**Title:** District Branch Chief

**Accompanied By:**

**Title:** District Branch Chief

Jim Bozionelos

**Signed:** 11/22/2023

**COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES**  
Please contact Life Safety North at (916) 568-3826 for assistance.



**DEPARTMENT OF FORESTRY AND FIRE  
PROTECTION**  
OFFICE OF THE STATE FIRE MARSHAL  
Fire and Life Safety Division - North  
2251 Harvard Street, Suite 130, Sacramento, CA 95815  
(916) 568-3826

## SPOT INSPECTION REPORT

### Violation # 697378

**Description:** 511335

**Violation Code:** Title 24 CEC 2022-400.12

**Comments:** Please remove the flexible electrical cord and replace with permanent wiring to the RV trailer.



**Comments:**

### Violation # 697376

**Description:** 510869

**Violation Code:** Title 24 CFC 2022-105.1.1

**Comments:** Permanent electrical installations shall be reviewed, permitted, and inspected by the Office of the State Fire Marshal. Please provide electrical plans for review and permitting.

A property owner or owner's authorized agent who intends to conduct an operation or business, or install or modify systems and equipment that are regulated by this code, or to cause any such work to be performed, shall first make application to the fire code official and obtain the required permit.