



**DEPARTMENT OF FORESTRY AND FIRE
PROTECTION**
OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - North
2251 Harvard Street, Suite 130, Sacramento, CA 95815
(916) 568-3826

SPOT INSPECTION REPORT

LOCATION INFORMATION

Building Name: Parking lot

Street Address: CAPITOL,L,29TH,30TH

County: Sacramento

City, State, Zip code: Sacramento, CA, 95814

Lot Number:

Suite Number:

Floor Number:

Agency: Transportation Dept. (CalTrans) (59900)

SFM File No.: 14-34-81-1034-10001

INSPECTION INFORMATION

Inspection Number : 152488

Inspection Type: Spot Inspection

Inspection Date : 11/28/2023

Inspection Status : Failed

Inspector: Cliff DuGranrut

Inspection Hours : 2

Inspector Signature: 

Travel Hours : 1

Inspection Comments: A Fire and Life Safety Inspection was conducted at CALTRANS Airspace Sac051-0002, on Tuesday, November 28, 2023 by Deputy State Fire Marshal Cliff DuGranrut. This inspection is for fire and panic safety, and code compliance within the California Department of Transportation (CALTRANS) right-of-way property use. I was accompanied by CALTRANS Staff. The location is a parking structure. The following deficiencies were noted and shall be correct. See deficiency list.
End of Report.

Discussed With: Jewan Sood

Title: R/W Agent Range B

Accompanied By: 

Title: R/W Agent Range B

Jewan Sood

Signed: 11/30/2023

Violation # 698751

Description: 365

Violation Code: Title 19 Title 19 Current-3.29

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact Life Safety North at (916) 568-3826 for assistance.



**DEPARTMENT OF FORESTRY AND FIRE
PROTECTION**
OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - North
2251 Harvard Street, Suite 130, Sacramento, CA 95815
(916) 568-3826

SPOT INSPECTION REPORT

Comments: Multiple cabinets are missing fire extinguishers. One of the extinguishers has been discharged and put back in the cabinet. Please replace the missing extinguisher. The discharged extinguisher needs to be replaced or serviced.

- (a) General. Portable fire extinguishers conforming to the requirements of, California Code of Regulations, Title 19, Division 1, Chapter 3 shall be installed and maintained in accordance with guides established therein.
- (b) Special Coverage. Additional Class A, B, and C units of adequate extinguishing potential shall be provided for any other hazard as determined by the enforcing agency.
- (c) Group A Occupancies.
 - (1) One additional Class 2-A unit shall be provided in Group A Occupancies as follows:
 - (A) On each side of the stage or platform.
EXCEPTION: Platforms 1000 square feet or less in area need have only one such extinguishing unit.
 - (B) On each side of every fly gallery.
 - (C) In basements beneath the stage or platform.
 - (D) In every hallway or passageway leading to a dressing room.
 - (E) In every property room, carpenter shop, or similar workroom.
 - (2) Not less than one 10-B: C unit (not less than 4-B: C for existing extinguishers in existing occupancies) shall be provided:
 - (A) For each motor and fan room.
 - (B) Adjacent to each switchboard on the stage or platform.
 - (C) For each motion picture machine in projection rooms.
EXCEPTION: One 20-B:C unit (not less than 8-B:C for existing extinguishers in existing occupancies) in each projection room may be accepted as providing substantially equal protection.
 - (3) The enforcing agency may allow modifications or deviations relative to the number and location of portable fire extinguishers as required by this section provided such authority finds that the basic intent of this section and the ease of accessibility to extinguishers is otherwise achieved.
- (d) Group R-2.1, R-3.1 and R-4 Occupancies. In Group R-2.1, R-3.1 and R-4 Occupancies a continuously attached garden hose, equipped with a water flow control nozzle, may be provided in lieu of one or more required fire extinguishers when acceptable to the enforcing agency. The location and length of such hose shall be as designated or approved by the enforcing agency.
NOTE: It is recommended that wherever possible portable fire extinguishers be located adjacent to manual fire alarm sending stations.



Comments:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact Life Safety North at (916) 568-3826 for assistance.



**DEPARTMENT OF FORESTRY AND FIRE
PROTECTION**
OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - North
2251 Harvard Street, Suite 130, Sacramento, CA 95815
(916) 568-3826

SPOT INSPECTION REPORT

Violation # 698751

Description: 365

Violation Code: Title 19 Title 19 Current-3.29

Comments: Multiple cabinets are missing fire extinguishers. One of the extinguishers has been discharged and put back in the cabinet. Please replace the missing extinguisher. The discharged extinguisher needs to be replaced or serviced.

(a) General. Portable fire extinguishers conforming to the requirements of, California Code of Regulations, Title 19, Division 1, Chapter 3 shall be installed and maintained in accordance with guides established therein.

(b) Special Coverage. Additional Class A, B, and C units of adequate extinguishing potential shall be provided for any other hazard as determined by the enforcing agency.

(c) Group A Occupancies.

(1) One additional Class 2-A unit shall be provided in Group A Occupancies as follows:

(A) On each side of the stage or platform.

EXCEPTION: Platforms 1000 square feet or less in area need have only one such extinguishing unit.

(B) On each side of every fly gallery.

(C) In basements beneath the stage or platform.

(D) In every hallway or passageway leading to a dressing room.

(E) In every property room, carpenter shop, or similar workroom.

(2) Not less than one 10-B: C unit (not less than 4-B: C for existing extinguishers in existing occupancies) shall be provided:

(A) For each motor and fan room.

(B) Adjacent to each switchboard on the stage or platform.

(C) For each motion picture machine in projection rooms.

EXCEPTION: One 20-B:C unit (not less than 8-B:C for existing extinguishers in existing occupancies) in each projection room may be accepted as providing substantially equal protection.

(3) The enforcing agency may allow modifications or deviations relative to the number and location of portable fire extinguishers as required by this section provided such authority finds that the basic intent of this section and the ease of accessibility to extinguishers is otherwise achieved.

(d) Group R-2.1, R-3.1 and R-4 Occupancies. In Group R-2.1, R-3.1 and R-4 Occupancies a continuously attached garden hose, equipped with a water flow control nozzle, may be provided in lieu of one or more required fire extinguishers when acceptable to the enforcing agency. The location and length of such hose shall be as designated or approved by the enforcing agency.

NOTE: It is recommended that wherever possible portable fire extinguishers be located adjacent to manual fire alarm sending stations.



**DEPARTMENT OF FORESTRY AND FIRE
PROTECTION**
OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - North
2251 Harvard Street, Suite 130, Sacramento, CA 95815
(916) 568-3826

SPOT INSPECTION REPORT



Comments: Discharged fire extinguishers.

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact Life Safety North at (916) 568-3826 for assistance.