



**DEPARTMENT OF FORESTRY AND FIRE
PROTECTION**

OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

SPOT INSPECTION REPORT

LOCATION INFORMATION

Building Name: Restroom

Street Address: 3165 KENDALL AVENUE

County: San Bernardino

City, State, Zip code: San Bernardino, CA, 92407

Lot Number:

Suite Number:

Floor Number:

Agency: Transportation Dept. (CalTrans) (59900)

SFM File No.: 14-36-11-0001-10010

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact Life Safety South at (626) 305-1908 for assistance.



DEPARTMENT OF FORESTRY AND FIRE PROTECTION

OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

SPOT INSPECTION REPORT

INSPECTION INFORMATION

Inspection Number : 152821 **Inspection Type:** Spot Inspection

Inspection Date : 12/05/2023 **Inspection Status :** Failed

Inspector: Leslie Compton **Inspection Hours :** 2

Inspector Signature: *Leslie Compton* **Travel Hours :** 0

Inspection Comments: On this date, December 5th, 2023, a annual inspection was conducted for the above facility by DSFM III (Specialist) Leslie Compton and Caltrans Right Away Agent Roger Gonzalez. During the inspection, the following was noted:
1. Unable to make access inside of the restroom during the inspection.
2. This location is an outside parking lot with bus stop.

Discussed With: Roger Gonzalez **Title:** Right Away Agent

Accompanied By: _____ **Title:** Right Away Agent
Roger Gonzalez

Signed:

Violation # 700375

Description: 510485

Violation Code: Title 19 Title 19 Current-3.07

Comments: Remove all combustible vegetation around outside electrical equipment near restrooms.



Comments: Electrical Equipment

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact Life Safety South at (626) 305-1908 for assistance.