



**DEPARTMENT OF FORESTRY AND FIRE
PROTECTION**
OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - North
2251 Harvard Street, Suite 130, Sacramento, CA 95815
(916) 568-3826

SPOT INSPECTION REPORT

LOCATION INFORMATION

Building Name: 1334 1338 W Fremont St.

Street Address: 1334/1338 West Fremont St

County: San Joaquin

City, State, Zip code: Stockton, CA, 95202

Lot Number:

Suite Number:

Floor Number:

Agency: Transportation Dept. (CalTrans) (59900)

SFM File No.: 14-39-81-0087-10001

INSPECTION INFORMATION

Inspection Number : 152695

Inspection Type: Spot Inspection

Inspection Date : 12/01/2023

Inspection Status : Failed

Inspector: Steven Mahoney

Inspection Hours : 1.5

Inspector Signature:

Travel Hours : 0

Inspection Comments: A Fire and Life Safety Inspection was conducted at CALTRANS Airspace 10-SJX005-0500, on Friday, December 1, 2023 by Deputy State Fire Marshal Ernie Artola and Steve Mahoney. This inspection is for fire and panic safety, and code compliance within the California Department of Transportation (CALTRANS) right-of-way property use. I was accompanied by CALTRANS Staff. The location is a multiple building property with automotive and marine repair shops. The following deficiencies were noted and shall be correct. See deficiency list. NOTE • Unable to access 1338 W. Fremont St. the occupant is out of the country. This will be inspected during the 30 day re-inspection.

End of Report

Discussed With: Shauna Bivens

Title: Right of Way Agent

Accompanied By:

Title: Right of Way Agent

Shauna Bivens

Signed:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact Life Safety North at (916) 568-3826 for assistance.



**DEPARTMENT OF FORESTRY AND FIRE
PROTECTION**

OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - North
2251 Harvard Street, Suite 130, Sacramento, CA 95815
(916) 568-3826

SPOT INSPECTION REPORT

Violation # 700111

Description: 510489

Violation Code: NFPA 13 2016-9.1.1.8.1

Comments: All material that is being stored on sprinkler pipe shall be removed.

Sprinkler piping or hangers shall not be used to support non-system components.